



JACKSON BUREAU OF FIRE SAFETY FIRE DISTRICT NO. 1 & 3

200 KIERYCH MEMORIAL DRIVE
JACKSON N.J. 08527

FRANK McDONNELL
FIRE OFFICIAL

Phone (732) 928-1666x14 Fax (732) 928-6500
fmcdonnell@jacksonfiredist3.org www.jacksonfiredist3.org




REQUIREMENT FOR "FIRE LANES" Fire District 3

All "FIRE LANES" shall be Twenty (20') feet wide bordered by a Four (4") inch wide yellow stripe on both sides and shall be approved traffic marking paint.

At every Fifty (50') foot interval of the Fire Lane the words "NO PARKING FIRE LANE" shall be painted within, with approved traffic marking paint. The size of the lettering is as follows: The below dimensions are for each letter.

TWENTY-FOUR (24") INCHES HIGH SIXTEEN (16") INCHES WIDE FOUR (4") INCH STROKE



REQUIREMENTS FOR "NO PARKING SIGNS"

Jackson Township Code Chapter 61-4 Addendum A Res. No. 3006 R 82



ALL 'NO PARKING' SIGNS SHALL BE ERECTED WITH THE BOTTOM OF THE SIGN NOT LESS THAN SIX (6') FEET ABOVE THE GROUND.

THE SIGN IS TO BE METAL WITH DIMENSIONS OF EIGHTEEN (18") INCHES WIDE; BY TWENTY-FOUR (24") INCHES HIGH, WITH A WHITE BACKGROUND AND RED LETTERS. THE SIZE OF THE LETTERS ARE AS FOLLOWS:

- LINE ONE - THREE (3") INCH LETTERS
- LINE TWO - THREE (3") INCH LETTERS
- LINE THREE - THREE (3") INCH LETTERS
- LINE FOUR - TWO (2") INCH LETTERS
- LINE FIVE - ONE (1") INCH LETTERS
- LINE SIX - ONE (1") INCH LETTERS
- LINE SEVEN - ONE (1") INCH LETTERS



NOTE: SIGN MUST COMPLY WITH ALL LOCAL FIRE DEPT. REQUIREMENTS.

REQUIREMENTS FOR "FIRE ZONES"

Fire District 3

ALL "FIRE ZONES" shall have diagonal stripes across the entire zone. All stripes and lettering shall be painted in traffic yellow; having a **Four (4") inch** stroke, and shall be an approved traffic marking paint. The lettering size shall be a minimum of:

TWENTY FOUR (24") INCHES HIGH SIXTEEN (16") INCHES WIDE FOUR (4") INCH STROKE

The above dimensions are for each letter. A fire zone sign shall also be posted according to the sign requirements .

