



JACKSON BUREAU OF FIRE SAFETY FIRE DISTRICT NO. 1 & 3

200 KIERYCH MEMORIAL DRIVE
JACKSON N.J. 08527




FRANK McDONNELL
FIRE OFFICIAL

Phone (732) 928-1666x14 Fax (732) 928-6500
fmcdonnell@jacksonfiredist3.org www.jacksonfiredist3.org

REQUIREMENT FOR "FIRE LANES" Fire District 1

All "FIRE LANES" shall be **Twenty (20')** feet wide bordered by a **Four (4")** inch wide yellow stripe on both sides and shall be approved traffic marking paint. At every **Fifty (50')** foot interval of the Fire Lane the words **"NO PARKING FIRE LANE"** shall be painted within, with approved traffic marking paint. The size of the lettering is as follows: The below dimensions are for each letter.
TWENTY-FOUR (24") INCHES HIGH SIXTEEN (16") INCHES WIDE FOUR (4") INCH STROKE



NOTES:

1. ALL "NO PARKING" SIGNS SHALL BE ERECTED WITH THE BOTTOM OF THE SIGN NOT LESS THAN SIX (6') FEET ABOVE THE GROUND.
2. THE SIGN IS TO BE METAL WITH DIMENSIONS OF EIGHTEEN (18") INCHES WIDE; BY TWENTY-FOUR (24") INCHES HIGH WITH A WHITE BACKGROUND AND RED LETTERS. THE SIZE OF THE LETTERS ARE AS FOLLOWS:
3. LINE ONE - THREE (3") INCH LETTERS
LINE TWO - THREE (3") INCH LETTERS
LINE THREE - THREE (3") INCH LETTERS
LINE FOUR - TWO (2") INCH LETTERS
LINE FIVE - ONE (1") INCH LETTERS
LINE SIX - ONE (1") INCH LETTERS
LINE SEVEN - THREE (3") INCH LETTERS
4. SIGN MUST COMPLY WITH ALL LOCAL FIRE DEPT. REQUIREMENTS.

NOTE

THE E
OR M,
PERM/
DOOR
GROUP

REQUIREMENTS FOR NO PARKING SIGNS "Fire District 1"



Jackson Township Code Chapter 61-4 Addendum A Res. No. 3006 R 82

REQUIREMENTS FOR "FIRE ZONES"
Fire District 1

ALL "FIRE ZONES" shall have diagonal stripes across the entire zone. All stripes and lettering shall be painted in traffic yellow; having a **Four (4") inch** stroke, and shall be an approved traffic marking paint. The lettering size shall be a minimum of:

TWENTY FOUR (24") INCHES HIGH SIXTEEN (16") INCHES WIDE FOUR (4") INCH STROKE

The above dimensions are for each letter. A fire zone sign shall also be posted according to the sign requirements.



FIRE DISTRICT 1