



**JACKSON BUREAU OF FIRE SAFETY  
FIRE DISTRICT NO. 1 & 3  
200 KIERYCH MEMORIAL DRIVE  
JACKSON N.J. 08527**



FRANK McDONNELL  
FIRE OFFICIAL


Phone (732) 928-1666x14 Fax (732) 928-6500  
[fmcdonnell@jacksonfiredist3.org](mailto:fmcdonnell@jacksonfiredist3.org) [www.jacksonfiredist3.org](http://www.jacksonfiredist3.org)

# “TRUSS BUILDING”

## Isosceles Triangle Signs

The emblem shall be of a bright and reflective color, or made of reflective material. The shape of the emblem shall be an Isosceles Triangle and the size shall be 12 inches Horizontally by 6 inches Vertically, with Letters of a size and color to make them Conspicuous, shall be printed on the emblem, as shown in diagram below.

TRUSS “FLOOR”



TRUSS “ROOF”



TRUSS  
“FLOORS & ROOF”



The emblem shall be permanently affixed to the LEFT of the main entrance door at the height of between 4 ft. and 6 ft. above the ground, and shall be installed and maintained by the Owner of the building.